



## KDER.E257069 Grounding and Bonding Equipment

[Page Bottom](#)

---

### Grounding and Bonding Equipment

[See General Information for Grounding and Bonding Equipment](#)

**HILTI INC**

E257069

7250 Dallas Pky , Legacy Tower Suite 1000  
Plano, TX 75024 USA

**Grounding connectors**, Cat. Nos. S-BT-ER M10/15 SN6, S-BT-ER W10/15 SN6, S-BT-EF M10/15 AN6, S-BT-EF W10/15 AN6, S-BT-ER M8/15 SN6, S-BT-EF M8/15 AN6, X-BT W10-24-6 SN12-R, X BT M10 24 6 SN12-R, X-BT W6-24-6 SN12-R, X-BT M6-24-6 SN12-R, X-BT-ER M6/7 SN4, X-BT-ER W6/7 SN4, X-BT-ER M8/7 SN4, X-BT-ER M10/3 SN4, X-BT-ER W10/3 SN4.

Carbon steel mounting surface: 5/16 inch minimum thickness for X-BT studs and 1/4 inch minimum thickness for S-BT studs.

Grounding connectors: Ring terminated copper or aluminum conductors.

Maximum ambient temperature: 100°C.

The X-BT studs installed with the aid of a power actuated tool, DX 351BT. The S-BT grounding connectors installed using a setting tool with appropriate depth gauge.

[Last Updated](#) on 2017-12-12

---

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".